

Test Certificate of Short-circuit and switching performance

Tested samples/items Withdrawable type three-phase vacuum circuit-breaker,
installed into an air insulated metal-enclosed switchgear

Designation ISM/TEL-4.76-31.5/1250-111D
Rated voltage 4,76 kV ; Rated normal current 1250 A ; Rated frequency 50/60 Hz

Manufacturer TAVRIDA ELECTRIC Co Ltd
Beijing P.R.CHINA

Tested for NPO TAVRIDA ELECTRIC
Solovieva St., Ioshkar Ola, Mariy-El. - RUSSIA

Tests date **from** September 29, 2008 **to** December 9, 2008

Tested by CESI S.p.A. - Milan - ITALY

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in the reference documents, identified in this certificate, has been subjected to the series of proving tests in accordance with

IEEE Std C37.09 (1999) and corrigendum (2007)
Sub Clauses 4.8 and 4.9

This Test Certificate has been issued by CESI in accordance with above mentioned Standards.

The results are shown in the record of Proving Tests and the oscillograms attached in the Test Reports. The values obtained and the general performance are considered to comply with the above Standards and to justify the ratings assigned by the Manufacturer as listed on page No.2.

This Test Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

Only integral reproduction of this Test Certificate or reproductions of this page accompanied by any pages on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from CESI.

No. of pages 3 **No. of pages annexed** -

Issue date April 16, 2009

Prepared QED - Beccarini Pierangelo

A9004280 2925 ALT

Verified OOR - Vercellotti Uberto, QED - Arneodo Giorgio

A9004280 2963 VER

A9004280 503476 VER

Approved LAP - Il Responsabile - Nicolini Roberto

A9004280 821814 APP

CESI S.p.A.

Energy Division

Technical Area Components

"Testing Laboratories"

Manager