

**Type Test Certificate of** Complete type tests

**Apparatus** Line trap

**Designation** SBS-N 4000/02  
Power frequency inductance 0,2 mH; Continuous rated current 4000 A; Rated frequency 50 Hz

**Manufacturer** SELTA S.p.A. – Cadeo (Piacenza) - Italy

**Tested for** SELTA S.p.A. – Cadeo (Piacenza) - Italy

**Date(s) of tests** **from** July 8, 2008 **to** February 16, 2009

**Tested by** CESI S.p.A. - Milan - ITALY

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in the reference documents, identified in this certificate, has been subjected to the series of proving tests in accordance with

**IEC 60353 (1989), with amendment 1 (2002)**

**This Type Test Certificate has been issued by CESI following exclusively the STL Guides.**

The results are shown in the record of Proving Tests and the oscillograms attached in the Test Reports. The values obtained and the general performance are considered to comply with the above Standards and to justify the ratings assigned by the Manufacturer as listed on page No.2.

The Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

Only integral reproduction of this Certificate, or reproductions of this page accompanied by any pages on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from CESI.

**No. of pages** 3 **No. of pages annexed** -

**Issue date** February 27, 2009

**Prepared** Unit LABORATORIES - D. Ronchi

**Prepared** PPR - Ronchi Daniele  
A9005536 2902 ALIT

**Verified** OOR - Pizzi Franco, QED - Arneodo Giorgio  
A9005536 3019 VER A9005536 2965 VER

**Approved** LAP - Nicolini Roberto  
A9005536 821814 APP

**CESI** S.p.A.

Energy Division

Technical Area Components

"Testing Laboratories"

Manager