

Test Certificate of Short-circuit and switching performance

Tested samples/items Three-phase vacuum circuit recloser

Designation OSM/TEL-27-12,5/630-205
Rated voltage 27 kV ; Rated normal current 630 A ; Rated frequency 50/60 Hz

Manufacturer NPO TAVRIDA ELECTRIC
Solovieva St., Ioshkar Ola, Mariy-El. - RUSSIA

Tested for NPO TAVRIDA ELECTRIC
Solovieva St., Ioshkar Ola, Mariy-El. - RUSSIA

Tests date **from** October 3, 2008 **to** October 8, 2008

Tested by CESI S.p.A. - Milan - ITALY

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in the reference documents, identified in this certificate, has been subjected to the series of proving tests in accordance with

IEEE Std C37.60 (2005-11)
Sub Clauses 6.3, 6.4 and 6.5

This Test Certificate has been issued by CESI in accordance with above mentioned Standards.

The results are shown in the record of Proving Tests and the oscillograms attached in the Test Reports. The values obtained and the general performance are considered to comply with the above Standards and to justify the ratings assigned by the Manufacturer as listed on page No.2.

This Test Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

Only integral reproduction of this Test Certificate, or reproductions of this page accompanied by any pages on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from CESI.

No. of pages 3 **No. of pages annexed** -

Issue date April 10, 2009

Prepared QED - Beccarini Pierangelo
A9008111 2925 ALT

Verified OOR - Vercellotti Uberto, QED - Arneodo Giorgio
A9008111 2963 VER A9008111 503478 VER

Approved LAP - Il Responsabile - Nicolini Roberto
A9008111 821814 APP

CESI S.p.A.
Energy Division
Technical Area Components
"Testing Laboratories"
Manager

