Type Test Certificate

Test Certificate of Complete Type Tests

Tested samples/items Pole of live tank SF6 circuit-breaker

Designation OFPI-550-63L-HAR

Rated voltage 550 kV; Rated normal current 6000 A; Rated frequency 50 Hz

Manufacturer Japan AE Power System Corporation

Landic Shinbashi Building, 8-3, Nishi-Shinbashi 3-chome, Minato-ku, Tokyo,

105-0003, Japan

Client Japan AE Power System Corporation

> Minato-ku, Tokyo, Landic Shinbashi Building, 8-3, Nishi-Shinbashi 3-ch

105-0003, Japan

from November 6, 2006 **Tests date**

March 1, 20

CESI S.p.A. - Milano - ITALY Tested by

> FGH-Engineering & Test GmbH - Mannheim -ERMANY

The apparatus, constructed in accordance with the description, drawings and photo raphs inc rporated in the reference documents, identified in this certificate, has been subjected to the series of proving tests in accordance with

IEC 62271-100 2006 Clause 6 IEC 6/271-110 (2005), Clause 6.115

This Test Certificate has been issued by CESI in accordance with above mentioned Standards.

The results are shown in the record of Proving Tests and the oscill grams attached in the Test Reports. The values obtained and the general performance are considered to comply with he above Standards and to justify the ratings assigned by the Manufacturer as listed on page No.2.

This Test Certificate applies only to the apparatus tested. Th responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer

Test Certificate or reproductions of this page accompanied by any pages on which are stated the endorsed bermitted without written permission from CESI. Only integral reproduction of this ratings of the apparatus ested, are permi

No. of pages

No. of pages annexed

Issue date December 3, 2009

Prepared QED - Beccarini Pierangelo

Verified QED - Arneodo Giorgio, OOR - Lo Monaco Franco

Approved LAP - Il Responsabile - Nicolini Roberto

PUBBLICATO A9034250 (PAD - 1272598)