

Type Test Certificate of Dielectric and temperature rise performance

Apparatus Low-voltage switchgear and controlgear assembly, three-phase with neutral bar, multi- cubicle-type

Designation Multi Cubicle Type Factory Built Assembly - 1600 A
Rated voltage 415 V ; Rated normal current 1600 A ; Rated frequency 50 Hz

Manufacturer Middle East Switchgear - P.O Box: 22984, Sharjah - U.A.E.

Tested for Middle East Switchgear - P.O Box: 22984, Sharjah - U.A.E.

Date(s) of tests **from** February 14, 2006 **to** February 14, 2006

Tested by CESI S.p.A. - Milan - ITALY

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in the reference documents, identified in this certificate, has been subjected to the series of proving tests in accordance with

IEC 60439-1 (2004-04), Clauses 8.2.1 and 8.2.2

This Type Test Certificate has been issued by CESI in accordance with above mentioned Standard.

The results are shown in the record of Proving Tests and the oscillograms attached in the Test Reports. The values obtained and the general performance are considered to comply with the above Standards and to justify the ratings assigned by the Manufacturer as listed on page No.2.

The Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

Only integral reproduction of this Certificate, or reproductions of this page accompanied by any pages on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from CESI.

No. of pages 3 **No. of pages annexed** -

Issue date April 30, 2010

Prepared QED - Beccarini Pierangelo
B0007727-2925 ALIT

Verified QED - Arneodo Giorgio, OOR - Vercellotti Uberto
B0007727-503478 VER B0007727-2963 VER

Approved LAP - The Manager - Nicolini Roberto
B0007727-821814 APP

CESI S.p.A.
Energy Division

Technical Area Components
"Testing Laboratories"
Manager