

**Type Test Certificate of** Switching Performance

**Apparatus** Three-phase SF6 circuit-breaker set in air-insulated metal-enclosed switchgear

**Designation** LF3  
Rated voltage 17,5 kV ; Rated normal current 3150 A ; Rated frequency 50-60 Hz

**Manufacturer** SCHNEIDER ELECTRIC - 9250 Rueil Malmaison - FRANCE

**Tested for** SCHNEIDER ELECTRIC - 9250 Rueil Malmaison - FRANCE

**Date(s) of tests** **from** February 25, 2010 **to** February 26, 2010

**Tested by** CESI S.p.A. - Milan - ITALY

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in the reference documents, identified in this certificate, has been subjected to the series of proving tests in accordance with

**IEC 62271-100 (2008)**  
**Sub-clause 6.111.9.1.4**

**This Type Test Certificate has been issued by CESI following exclusively the STL Guides.**

The results are shown in the record of Proving Tests and the oscillograms attached in the Test Reports. The values obtained and the general performance are considered to comply with the above Standards and to justify the ratings assigned by the Manufacturer as listed on page No.2.

The Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

Only integral reproduction of this Certificate, or reproductions of this page accompanied by any pages on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from CESI.

**No. of pages** 3 **No. of pages annexed** -

**Issue date** April 20, 2010

**Prepared** QED - Beccarini Pierangelo  
B0010759 2925 ALT

**Verified** QED - Arneodo Giorgio, OOR - Alunni Roberta  
B0010759 503478 VER B0010759 3083 VER

**Approved** LAP - The Manager - Nicolini Roberto  
B0010759 821814 APP

**CESI S.p.A.**  
Energy Division  
Technical Area Components  
"Testing Laboratories"  
Manager