January 20



Page 1





Test Certificate of Electrical and non-electrical type tests on cable

Tested samples/items Power cable with extruded insulation

Designation 20 kV XLPE insulated cable, PVC sheathed, with aluminium conductor

400 mm², copper wire screen 35 mm²

Rated voltage 12/20 kV; Max. operation voltage 24 kV

Manufacturer Guangdong Nanyang

Cable Group Holding Co. Ltd. (NANC)

Shantou - CHINA

Client Guangdong Nanyang

Cable Group Holding Co. Ltd. (NANC)

Shantou - CHINA

Tests date from October 2010

Tested by IPH GmbH - Berlin - GERMANY

Subsidiary Company of CESI S.p.A. Milar

phs incorporated in the reference documents, identified in The apparatus, constructed in accordance with the description, drawings and photographic this certificate, has been subjected to the series of proving tests in ac

> IEC 60502-2 clauses 18. and **D**.1 to 19.22

This Test Certificate has been issued by CESI accordance with above mentioned Standards.

The results are shown in the record of Proving Tests and the oscillograms attached in the Test Reports. The values obtained and the general performance are considered to comply with the above Standa ds and to justify the ratings assigned by the Manufacturer as listed on page No.2.

This Test Certificate applies only to the apparatus tested. he responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

Only integral reproduction of this Test Certificate, or reproductions of this page accompanied by any pages on which are stated the endorsed ratings of the apparatas tested, are permitted without written permission from CESI.

No. of pages No. of pages annexed

May 03, 2011 **Issue date**

Prepared IPH Laboratories - Günther Brose

CESI Laboratories - Giorgio Arneodo

Verified IPH Laboratories - Hannes Zinnbauer

CESI Laboratories - Maurizio Nervetti

Approved CESI Laboratories - Lorenzo Arcidiaco Testing & Certification Division sting Operations Area 'Milan Platform'