

Type Test Certificate of Complete type test

Apparatus Toughened glass cap & pin insulator units for a.c. systems

Designation E40/110

Mechanical failing load: 40 kN
 Wet power frequency withstand voltage (for a short string of 5 units): 136 kV
 Dry lightning impulse withstand voltage (for a short string of 5 units): 315 kV

Manufacturer SGD LA GRANJA VIDRIERIA S.L.
 Paseo del Pocillo s/n 40100 Granja, Spain

Client SGD LA GRANJA VIDRIERIA S.L.
 Paseo del Pocillo s/n 40100 Granja, Spain

Tested by CESI S.p.A: Milan, Italy

Tests date from January 10, 2011 to February 11, 2011

The apparatus, constructed in accordance with the description, drawings and photographs incorporated in the reference documents identified in this Certificate, has been subjected to the series of proving tests in accordance with

IEC 60383-1: 1993 Clauses 13, 14, 17, 19, 20

This Type Test Certificate has been issued by CESI in accordance with above mentioned Standard(s). The results are shown in the record of Proving Tests and the oscillograms attached in the Test Reports. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the ratings assigned by the Manufacturer as listed on page No. 3.

The Certificate applies only to the apparatus tested. The responsibility for conformity of any apparatus having the same designations with that tested rests with the Manufacturer.

Only integral reproduction of this Certificate, or reproductions of this page accompanied by any pages on which are stated the endorsed ratings of the apparatus tested, are permitted without written permission from CESI.

No. of pages 4 **No. of pages annexed** -

Issue date December 12, 2011

Prepared PPR - Beccarini Pierangelo
B1038193 2925 AUT

Verified PPR - Arneodo Giorgio, TPI - Sironi Alberto
B1038193 1800809 VER B1038193 3025 VER

Approved PMI - The Manager - Arcidiaco Lorenzo
B1038193 821814 APP

CESI S.p.A.
 Testing & Certification Division
 Testing Operations Area
 "Milan Platform"
 Manager

PUBBLICATO B1038193 (PAD - 1579635)

Mod. RPRO v. 8